

IQH1-18GM-V1



- Operating frequency 13.56 MHz
- Conforms to ISO 15693
- Suitable for FRAM transponder
- Read/write head with thread M18 x 1
- Connection via V1 (M12 x 1) plug connection
- Multihole-LED for function display
- Degree of protection IP67
- For connection to IDENTControl control interface

HF read/write head, ISO 15693, for IDENTControl










Dimensions



Technical Data

General specifications	
Operating frequency	13.56 MHz
Transfer rate	26 kBit/s
Sensing range	
Read distance	0 50 mm
Write distance	0 50 mm
Width	max. 45 mm
UL File Number	E87056 only from low voltage, limited energy source (SELV or PELV) or listed Class 2 source
Functional safety related parameters	
MTTF _d	750 a
Mission Time (T _M)	10 a
Diagnostic Coverage (DC)	0 %
Indicators/operating means	
LED green/yellow	Multihole-LED: green: power on green flashing: read/write attempt performed yellow: data carrier detected


Release date: 2020-04-24 Date of issue: 2020-04-24 Filename: 204622_eng.pdf

Technical Data

Electrical specifications		
Power consumption	P_0	≤ 1.2 W
Supply		from the IDENTControl
Directive conformity		
Radio equipment		
Directive 2014/53/EU		EN 301489-1 EN 301489-3 EN 300330 EN 62368-1 EN 50364
RoHS		
Directive 2011/65/EU (RoHS)		EN 50581
Standard conformity		
Degree of protection		EN 60529
RFID		ISO/IEC 15693-2 ISO/IEC 15693-3 ISO/IEC 18000-3
Approvals and certificates		
FCC approval		This device complies with part 15 of the FCC rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) This device must accept any interference received, including interference that may cause undesired operation. Caution: Changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.
KCC approval		KCC-CRI-PF1-IQH1-18GM-V1
Ambient conditions		
Ambient temperature		-25 70 °C (-13 158 °F)
Storage temperature		-40 85 °C (-40 185 °F)
Mechanical specifications		
Degree of protection		IP67
Connection		connector M12 x 1
Material		
Housing		PBT/stainless steel
Encapsulation compound		CY 221/HY 2966
Installation		non-flush
Distance between two heads		Multiplex on: ≥ 30 mm Multiplex off: ≥ 80 mm
Mass		approx. 40 g

Connection





Accessories

99

IC-KP-B6-V15B	Control interface unit IDENTControl with PROFIE
---------------	---

IBUS DP interface



 ${\tt IDENTControl\ control\ interface\ with\ Ethernet\ interface\ for\ TCP/IP,\ PROFINET,\ EtherNet/IP,\ and\ MODBUS\ TCP\ protocols}$



Release date: 2020-04-24 Date of issue: 2020-04-24 Filename: 204622_eng.pdf

Accessories IC-KP2-2HRX-2V1 Control interface unit IDENTControl Compactwith serial interface RS-232 and RS-485 IC-KP2-2HB6-V15B Control interface unit IDENTControl Compact with interface for PROFIBUS DP IC-KP2-2HB17-2V1D IDENTControl Compact control interface with Ethernet interface for TCP/IP, PROFINET, EtherNet/IP, and MODBUS TCP protocols IC-KP2-2HB21-2V1D Control interface unit IDENTControl Compact with EtherCAT interface IQC21-8 10pcs Data carrier IQC21-10 10pcs Data carrier IQC21-12.4 10pcs Data carrier IQC21-16 50pcs Data carrier IQC21-30 25pcs Data carrier IQC21-50F-T10 Data carrier Data carrier IQC21-58 IQC22-22-T9 50pcs Data carrier IQC33-20 50pcs Data carrier IQC33-30 25pcs Data carrier IQC33-50 25pcs Data carrier V1-G-2M-PUR-ABG-V1-W Connecting cable, M12 to M12, PUR cable 4-pin, shielded V1-G-5M-PUR-ABG-V1-W Connecting cable, M12 to M12, PUR cable 4-pin, shielded V1-G-10M-PUR-ABG-V1-W Connecting cable, M12 to M12, PUR cable 4-pin, shielded

Safety Information

This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.